Certificate of Conformity for AFILS according to IEC 60118-4



Listen to the difference

Desig	gned to be us	ed in co	njunction	with th	ne test ar									
1	Volumo o	fuco		Seated only:			ine require Typical:			eight for hearing aid use Possible range: 1.0m to 1.4m				
1 Volume of use				Standing:			Typical:					n to 2.0m		
Sketch of floorplan, and target coverage area: (indicate scale / dimensions)														
Det	ermine 4 to 6	points (e.g. A to	F) insid	de the flo	orplan to	examine -	center,	corner, s	sides, fro	nt / ba	ck etc		
Measurement point				Α	В	С	D	Е	F	G	Н	J	K	
height (in meters) =														
2 Background noise				In			et coverag					s >-22dB s >-32dB		
	initial				Indicate		JIEITI ZOTIES	S OII LITE I	loorpian		Aleas	-32ub		
3	Field strength final													
					4.0				ID 1.41		4111			
	Frequency response				10	UHz and	5kHz shou	la be ±30	dB relativ	ve to the	1KHZ r	reading		
		initial	100Hz											
			1kHz											
4			5kHz											
			100Hz											
		final	1kHz											
			5kHz											
5	Field stre	nath	confirm											
							Yes							
6	Overspill		Is test required?											
7	System u	se												
Customer:					Installer Co: Equipment:									
Venue:					Installer Name: Serial No(s)									
Roc					Comments:									
Other details:														
Declaration that the system has been Signed:											T. D. :	ı.		
Declaration that the system has been commissioned to achieve performance as											Dated	u.		
l `	required by IEC60118-4.													